

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 295Dated: 05/06/2026It is certified that an inspection team headed by Ravi kelwa(Name of Officers with designation) from Ravi kelwa S.O.D. (PHE.)PHED inspected the **SARASWATI GRAMODAYA HIGHER SECONDARY SCHOOL, GOVIND NAGAR, PALIYA PIPARIYA,****TEHSIL-BANKHEDI, DIST.- NARMADAPURAM, MP** on 09/03/2026 and on the basis of Water TestReport (Attached) bearing no. DWTLHBD/F-04/7.8/F-27 dated 11/03/2026of D.W.L.T. / PHED/ Narmadapuram (PHED Lab)

certified that the **SARASWATI GRAMODAYA HIGHER SECONDARY SCHOOL, GOVIND NAGAR, PALIYA PIPARIYA,**
TEHSIL-BANKHEDI, DIST.- NARMADAPURAM, MP has safe drinking water facilities for the students and members
 of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the
 campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till one year

Signature with seal

:-

Suman
ASSISTANT ENGINEER
 Public Health Engg. Sub Div.
 PIPARIYA (M. P.)

Name

:-

Designation

:-

Name & address of the office/Department: - AE. PHE sub Division pipariya
pin 461775

To,

SARASWATI GRAMODAYA HIGHER SECONDARY SCHOOL, GOVIND NAGAR,
PALIYA PIPARIYA, TEHSIL-BANKHEDI, DIST.- NARMADAPURAM, MP

(Name and address of the institution)

Note: The certificate is to be issued by authorized officer / PHED Lab/local bodies

प्रमाणित
 सरस्वती ग्रामोदय उ. मा. वि.
 गोविन्द नगर, पलिया पिपरिया

सचिव
 सरस्वती ग्रामोदय
 शिक्षा विकास समिति

अध्यक्ष
 सरस्वती ग्रामोदय उ. मा. विद्यालय
 गोविन्दनगर, पलिया पिपरिया

DWTLHBD/F-04 /7.8/F-27



DISTRICT WATER TESTING LABORATORY

Public Health Engineering Department

Kothi Bazar ,Narmadapuram (M.P) 461001

TC - 15038

Test Report

Status of Sample	Drinking Water	Unique Identification NO.	
Sender's name	Saraswati Gramodaya HSS School GovindNagar-	Sender's letter no.	
Sender's address	District : Narmadapuram	Sender's letter date	09-03-2026
		Start Date of Analysis	10-03-2026
Quantity of sample	1000 ml	DWTL receipt No.	
Sample collected by lab(YES/NO)	No	End Date of Analysis	11-03-2026

Sample details:

S.No	Block	Gram panchyat	Village/Town	Habitation	Location
1	Bankhedi	Paliya Pipariya	Paliya Piapariya	Paliya Pipariya	HSS School Govind Nagar Tape water
2					

Physical &Chemical Test Report With Details of Parameters Their Test Methods ,Units and specifications as per BIS.

S. No	Characteristics	Test Method (BIS 10500:2012)	Unit	As per BIS 10500:2012&Reaffirmed in Sep.2018		Test Result					
				Requirement (Desirable)	Permissible Limit in the absence of Alternate Source	Sample 1	Sample 2	Sample 3	Sample 4	Sample 5	Sample 6
1	2	3	4	5	6	7					
1	Temperature	°C									
2	Colour	BIS :3025 Part 4	Hazen scale	5	15	2.0					
3	Odour	BIS :3025 Part 5	aggregable		Aggregable	A					
4	Taste	BIS :3025 Part 8	aggregable		Aggregable	A					
5	Iron as Fe	BIS :3025 Part 53	Mg/l	1.0	1.0	0.10					

771

[Signature]

प्राचार्य

सरस्वती ग्रामोदय उ.मा. विद्यालय
गेविंदनगर, पलियापिपरिया, तह. बनखेडी


[Signature]
CHAIRMAN

Saraswati Gramodaya U.M.A. Vidyalaya
Govindnagar, Paliyapihariya, Tah. Bankehi

6	Nitrate as No3	BIS :3025 Part 34	Mg/l	45	45	5.0					
7	Fluoride as F	BIS :3025 Part 60	Mg/l	1.0	1.5	0.10					
8	Chloride as Cl	BIS :3025 Part 32	Mg/l	250	1000	40.0					
9	Total Alkalinity as CaCO3	BIS :3025 Part 23	Mg/l	200	600	300					
10	Calcium as Ca++	BIS :3025 Part 40	Mg/l	75	200	81.6					
11	Magnesium as Mg	BIS :3025 Part 46	Mg/l	30	100	28.8					
12	Total Hardness as CaCO3	BIS :3025 Part 21	Mg/l	200	600	324					
13	Sulphate as SO4	BIS :3025 Part 24	Mg/l	200	400	32.6					
14	pH	BIS :3025 Part 2	pH scale	6.5 to 8.5	6.5 to 8.5	7.04					
15	Turbidity	BIS :3025 Part 10	NTU	1.0	5.0	2.2					
16	Conductivity	BIS :3025 Part 14	µmho/cm	-	-	1012					
17	TDS	BIS :3025 Part 16	Mg/l	500	2000	658					
18	Fecal Collform (TTC)		Per 100 ml	Nil	Nil	0.00					
19	Total Coloform		Per 100 ml	Nil	Nil	0.00					
20	Residual Cl2			0.2	1.0	nil					

1. This report should not be produced partly or full without approval of signatory authority for legal purpose.
2. It is recommended that acceptable limit is to be implemented. Values in excess of those mentioned under "acceptable" render the water not suitable, but still may be tolerated in the absence of an alternative source but the limit indicated under the "permissible limit in the absence of alternative source" in column 6, above with the sources will have to be rejected.
3. The results refer only to tested Sample and parameter tested.
4. Sample will be stored for a period of 15 days from the date of issue of report (for tests from serial No 1,5,6,7,13,18,19,20).
5. This lab does not hold any responsibility for variation in results for samples kept on hold and want to clarification.
6. The tests marked with an * are not under the process of accreditation by NABL.

प्राचार्य
सरस्वती ग्रामोदय उ.मा. विद्यालय
नेविंदनगर, पलियापिपरिया, तह. बन्नेदी
जिला नर्मदापुरम (म.प्र.)


Chemist
District Water Testing Laboratory
P.H.E.D. Narmadapuram
WATER TESTING LABORATORY
P.H.E. Division
Narmadapuram (M.P.)


CH. अध्यक्ष
सरस्वती ग्रामोदय विद्यालय
नेविंदनगर, पलियापिपरिया
School, Sovindnagar